

COMMONWEALTH OF KENTUCKY
CITY OF LONDON
ORDINANCE NO. 2006-10


AN ORDINANCE ESTABLISHING PRETREATMENT LIMITATIONS
RELATING TO WATER QUALITY, WASTE WATER TREATMENT PLANT
OPERATIONS AND SLUDGE QUALITY OF "TYPE B" SLUDGE.

Whereas, the Kentucky Department for Environmental Protection, Division of Water, has reevaluated and revised its limitations for the City of London's wastewater treatment, and has advised the City of London of the same, all of which relates to water quality, wastewater treatment plant operations, and sludge quality of "Type B" sludge as defined in 401 KAR 45:100,

(1) BE IT ORDAINED AS FOLLOWS:

<u>Pollutant</u>	<u>Daily Maximum</u> (Milligrams per liter)
<u>Arsenic</u>	0.22
<u>Cadmium</u>	0.05
Chromium, Hexavalent	1.24*
Chromium, Total	2.31
<u>Copper</u>	1.47
<u>Cyanide</u>	0.43
<u>Lead</u>	0.25
Mercury	0.0003
Molybdenum	0.75*
<u>Nickel</u>	1.57
Phosphorus, Total	10
Selenium	0.66*
<u>Silver</u>	0.43
Zinc	1.48

- (2) All Ordinances or parts of Ordinances in conflict with this Ordinance are repealed.
- (3) This Ordinance shall become effective immediately upon publication.



Mayor Kenneth Smith
City of London

Attested:



Connie McKnight, City Clerk

First Reading: 6/5/06
Second Reading:
Publication Date: