

COMMONWEALTH OF KENTUCKY
CITY OF LONDON
ORDINANCE NO. 937

AN ORDINANCE REVISING PRETREATMENT LIMITATIONS BY AMENDING ORDINANCE NO. 840 ENTITLED “AN ORDINANCE OF THE CITY OF LONDON CONCERNING USE OF THE MUNICIPAL SANITARY SEWAGE COLLECTION AND TREATMENT SYSTEM, SETTING FORTH POLICY, DEFINITIONS, RULES AND REGULATIONS REGARDING THE USE OF SAID SYSTEM, CONTROLLING PRIVATE WASTEWATER DISPOSAL, GOVERNING THE BUILDING OF SEWERS AND CONNECTIONS, POLLUTION DISCHARGE LIMITS, PRETREATMENT PROGRAM ADMINISTRATION, ESTABLISHING THE RIGHT OF THE CITY TO CHARGE FEES FOR ADMINISTERING THE CITY’S REASONABLY NECESSARY FUNCTIONS RELATED TO SEWER USE, AND DELINEATING POWERS AND AUTHORITY OF INSPECTORS AND SETTING FORTH THE METHODS AND PROCEDURES OF ENFORCEMENT OF THE ORDINANCE AND PENALTIES FOR VIOLATION OF SAME AND REPEALING PRIOR ORDINANCES.”


Whereas, the Kentucky Department For Environmental Protection, Division of Water, has reevaluated and revised its limitations for the City of London’s wastewater treatment, and has advised the City of London of the same, all of which relates to water quality, wastewater treatment plant operations, and sludge quality of “Type B” sludge as defined in 401 KAR 45:100,

BE IT ORDAINED AS FOLLOWS:

1. That Paragraph 11, page 15 of Ordinance No. 840 be and is hereby amended to read as follows:

<u>Pollutant</u>	<u>Daily Maximum</u> (in milligrams per liter)
Arsenic	0.04
Cadmium	0.02
Chromium, Total	2.31
Copper	0.24
Cyanide, Amenable	0.01
Lead	0.09
Mercury	0.0003
Nickel	0.30
Silver	0.10
Zinc	1.48

2. All other parts of Ordinance No. 840 remain unchanged and are unaffected by this ordinance amendment.
3. This amendment shall become effective immediately upon publication.



Mayor Kenneth Smith
City of London

Attested:



Connie McKnight
City Clerk

First Reading Date: 1/26/98
Second Reading Date: 2/9/98
Publication Date: 2/13/98